

VENKATESH ENTERPRISES

Shop No. 4, Mahanagarpalika Complex, Behind Panchavati Talkies, Ichalkaranji-416115 Dist- Kolhapur (MS)

Contact : 9822967981/7676223939, Email ID-venkyfiresafety@gmail.com

State : 27 Maharashtra

Pan No- CJIPP6389J

GST NO- 27CJIPP6389J1ZC

CERTIFICATE

No. : 22

Dear Sir,

This to Certify that, We are Authorised Maintenace Contractor of Fire Extinguishers
We have to tested / fresh Refiled / Serviced All Existing 8.00 Nos. fire Ext. of

To, DOC. S.P. PATIL AYURVEDIC MEDICAL COLLEGE

Korochi KORochi GSTNO-

Testing Date : 14/02/2026

Next Due Date : 13/02/2027

S.N	Type of Extingulshers	Quantity	Capacity	Refilling	Servising	H. P Testing	Remark
1	REFF.& SERV.FOR ABC TYPE F/E	8.00	6 KG	OK	OK	OK	OK
		8.00					

The above Fire Extinguisher's Are Now in Perfect Working Conditon

FOR VENKATESH ENTERPRISES



Authorised Signatory

VENKATESH ENTERPRISES

Shop No. 4, Mahanagarपालिका Complex, Behind Panchavati Talkies, Ichalkaranji-416115 Dist- Kolhapur (MS)

Contact : 9822967981/7676223939, Email ID-venkyfiresafety@gmail.com

State : 27 Maharashtra

Pan No- CJIPP6389J

GST NO- 27CJIPP6389J1ZC

CERTIFICATE

No. : 23

Dear Sir,

This to Certify that, We are Authorised Maintenance Contractor of Fire Extinguishers
We have tested / fresh Refilled / Serviced All Existing 4.00 Nos. fire Ext. of

To, SHREE BHAIKAVNATH SHIKSHAN VA SEVABHAVI SANSTHA

Korocho KOROCHI GSTNO-

Testing Date : 14/02/2026

Next Due Date : 13/02/2027

S.N	Type of Extinguishers	Quantity	Capacity	Refilling	Servicing	H. P Testing	Remark
1	REF. & SERV. FOR ABC TYPE F/E	4.00	6 KG	OK	OK	OK	OK
		4.00					

The above Fire Extinguisher's Are Now in Perfect Working Condition

FOR VENKATESH ENTERPRISES



Authorised Signatory

VENKATESH ENTERPRISES

Shop No. 4, Mahanagarpalika Complex, Behind Panchavati Talkies, Ichalkaranji-416115 Dist- Kolhapur (MS)

Contact : 9822967981/7676223939, Email ID-venkyfiresafety@gmail.com

State : 27 Maharashtra

Pan No- CJIPP6389J

GST NO- 27CJIPP6389J1ZC

CERTIFICATE

No. : 24

Dear Sir,

This to Certify that, We are Authorised Maintenace Contractor of Fire Extinguishers
We have to tested / fresh Refiled / Serviced All Existing 4.00 Nos. fire Ext. of

To, AYURVEDIC CARE HOSPITAL KOROCHI

Korochi KOROCHI GSTNO-

Testing Date : 14/02/2026

Next Due Date : 13/02/2027

S.N	Type of Extingulshers	Quantity	Capacity	Refilling	Servising	H. P Testing	Remark
1	REFE.& SERV.FOR ABC TYPE F/E	4.00	6 KG	OK	OK	OK	OK
		4.00					

The above Fire Extinguisher's Are Now in Perfect Working Conditon

FOR VENKATESH ENTERPRISES



Authorised Signatory